



## Metro-West Building Officials

October 10, 2022

### GOOD DAY TO OUR MEMBERSHIP:

Just a reminder and information for attendees at our monthly meetings at the Grafton Public Library. The following information:

1. Absolutely **no smoking on premises** or **throwing cigarette** on town property.
2. Please use the rear parking lot when attending the meetings. The front parking spaces are for the general public and seniors using the library.
3. On receiving credit for attending our seminars
  - **Current Members** will receive credit when attending in-person and via online (zoom) meeting, **you must provide your full name and membership number as your screen name so we may properly credit you**
  - Non-members will receive two (2) free seminars whether in person or online. **Must** inform Mr. Berger you are planning to attend meeting for pre-registration send email to [robert.berger@mwboa.org](mailto:robert.berger@mwboa.org) subject line non-member attending monthly meeting
  - If you exceed your two (2) free seminars, you can either join or pay \$25.00 per seminar to MWBOA to receive credit from the Commonwealth or ICC.

Thank you for you cooperation

we look forward to seeing you at the next meeting

Best Regards

*Tin Htway*

Tin Htway  
Vice President



PREFERRED  
EDUCATION  
PROVIDER

Provider No. 2510 Course No.

## **Metro-West Building Officials**

### **Meeting Notice**

**October 18, 2022**

**9:00 AM -12:00 PM**



**Place: Grafton Library**  
**35 Grafton Common**  
**Grafton, MA 01519**

or

**[Join by Zoom](#)**

### **This month's presentation's**


**Building Code; Mechanical / HVAC Systems; Residential Construction**

This seminar is offered to Metro-West Building Officials & code enforcement officials to help explain manual J, D and S relating to residential HVAC systems

present by

**Michael S. Brogan**

brings over twenty years of experience as a mechanical and residential contractor, as well as four years as a local building inspector in the Commonwealth of Massachusetts. He is widely recognized, across Massachusetts, as an expert on mechanical (aka Sheet Metal) building permits and all things related to mechanical systems. He is licensed as both a Master Sheet Metal Worker and a Local Inspector in the Commonwealth of Massachusetts. Prior to joining the MCC team, Michael served as the local inspector for the Town of Norfolk, MA.



# MICHAEL S. BROGAN

1116 Great Plain Ave, Ste 207 • Needham, MA 02492  
(617) 930-9004 • mbrogan@planreviewers.com

---



## PROFESSIONAL PROFILE

Michael Brogan brings over twenty years of experience as a mechanical and residential contractor, as well as four years as a local building inspector in the Commonwealth of Massachusetts. He is widely recognized, across Massachusetts, as an expert on mechanical (aka Sheet Metal) building permits and all things related to mechanical systems. He is licensed as both a Master Sheet Metal Worker and a Local Inspector in the Commonwealth of Massachusetts. Prior to joining the MCC team, Michael served as the local inspector for the Town of Norfolk, MA.

## EXPERTISE

Building code; mechanical / HVAC systems; residential construction

## NOTABLE PROFESSIONAL EXPERIENCE

- Operations Manager, Municipal Code Consulting LLC (2019 – Present)
- Building Inspector / Plans Examiner, Municipal Code Consulting LLC (2018 – Present)
- Building / Mechanical Inspector, Town of Norfolk MA (2015 – 2018)
- Owner, Michael Brogan Contracting, Norfolk MA (2000 – Present)
- Owner, Airworks HVAC & Plumbing Inc, Norfolk MA (1994 – Present)

## RELEVANT LICENSES / CERTIFICATIONS

- MA Certified Building Official – Local Inspector
- MA Master Sheet Metal Worker – Unrestricted
- MA Pipefitter License

## RELEVANT PROJECTS

- Rosebrook Place, Wareham MA – Pre-occupancy commissioning of a 65-unit residential structure (all life safety and fire protection systems)
- Aquinnah Wampanoag Casino, Aquinnah MA – Design plan review and coordination of inspections for the proposed casino
- 400 Ocean Ave, Revere MA – Plan review of a new high-rise hotel (mechanical and architectural features)
- 1827 Bridge Street, Dracut MA – Plan review of mechanical systems for a new ~100,000 square foot assisted living facility with approx. 180 residential units
- Longplex, Tiverton RI – Inspection of mechanical and life safety systems
- Sugarbush Meadow, Sunderland MA – Principal mechanical plans examiner and building inspections (all phases)

company addresss, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

## Cooling Equipment

### Design Conditions

Outdoor design DB:	83.0°F	Sensible gain:	9000 Btuh	Entering coil DB:	76.3°F
Outdoor design WB:	69.7°F	Latent gain:	1654 Btuh	Entering coil WB:	62.9°F
Indoor design DB:	75.0°F	Total gain:	10654 Btuh		
Indoor RH:	50%	Estimated airflow:	473 cfm		

need to be filled in for  
ac equipment

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Split AC		
Manufacturer:	American Standard	Model:	4A7A3018H1+C(A,C,D,E)30B44+S9X2B040U3PS+TDR
Actual airflow:	473 cfm		
Sensible capacity:	12070 Btuh	134% of load	
Latent capacity:	2130 Btuh	129% of load	
Total capacity:	14200 Btuh	133% of load	SHR: 85%

70-85% correct value

## Heating Equipment

### Design Conditions

Outdoor design DB:	6.7°F	Heat loss:	20145 Btuh	Entering coil DB:	68.4°F
Indoor design DB:	70.0°F				

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type:	Gas furnace		
Manufacturer:	American Standard	Model:	ADH1B040A9H21B*
Actual airflow:	473 cfm		
Output capacity:	38000 Btuh	189% of load	

Temp. rise: 50 °F

needs to be  
completed

must have this  
statement

Meets all requirements of ACCA Manual S.



company addresss, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

## Cooling Equipment

### Design Conditions

Outdoor design DB:	83.0°F	Sensible gain:	9678 Btuh	Entering coil DB:	76.4°F
Outdoor design WB:	69.7°F	Latent gain:	1500 Btuh	Entering coil WB:	63.0°F
Indoor design DB:	75.0°F	Total gain:	11178 Btuh		
Indoor RH:	50%	Estimated airflow:	470 cfm		

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split AC  
Manufacturer: American Standard Model: 4A7A3018H1+C(A,C,D,E)30A2G+S9X2B040U3PS+TDR  
Actual airflow: 470 cfm  
Sensible capacity: 11985 Btuh 124% of load  
Latent capacity: 2115 Btuh 141% of load  
Total capacity: 14100 Btuh 126% of load SHR: 85%

## Heating Equipment

### Design Conditions

Outdoor design DB:	67°F	Heat loss:	22886 Btuh	Entering coil DB:	67.5°F
Indoor design DB:	70.0°F				

### Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Gas furnace  
Manufacturer: American Standard Model: ADD2A040A9242A\*  
Actual airflow: 470 cfm  
Output capacity: 32000 Btuh 140% of load  
Temp. rise: 50 °F

Meets all requirements of ACCA Manual S.

must have this  
statement



# Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form  
RPER 1  
15 Mar 09

## Header Information

Contractor:	company name your name	REQUIRED ATTACHMENTS	ATTACHED
Mechanical license:	<b>**must have lic. type and #**</b>	Manual J1 Form (and supporting worksheets):	Yes <input type="checkbox"/> No <input type="checkbox"/>
Building plan #:		or MJ1AE Form* (and supporting worksheets):	Yes <input type="checkbox"/> No <input type="checkbox"/>
Home address (Street or Lot#, Block, Subdivision):	123 main st, 1stfl	OEM performance data (heating, cooling, blower):	Yes <input type="checkbox"/> No <input type="checkbox"/>
		Manual D Friction Rate Worksheet:	Yes <input type="checkbox"/> No <input type="checkbox"/>
		Duct distribution sketch:	Yes <input type="checkbox"/> No <input type="checkbox"/>

## HVAC LOAD CALCULATION (IRC M1401.3)

### Design Conditions

#### Winter Design Conditions

Outdoor temperature: 7 °F  
Indoor temperature: 70 °F  
Total heat loss: 20145 Btuh

#### Summer Design Conditions

Outdoor temperature: 83 °F  
Indoor temperature: 75 °F  
Grains difference: 25 gr/lb @ 50% RH  
Sensible heat gain: 10227 Btuh  
Latent heat gain: 1880 Btuh  
Total heat gain: 12106 Btuh

### Building Construction Information

#### Building


Orientation: Front Door faces Southwest  
North, East, West, South, Northeast, Northwest, Southeast, Southwest

Number of bedrooms: 3  
Conditioned floor area: 1008 ft<sup>2</sup>  
Number of occupants: 2

#### Windows

Eave overhang depth: 0 ft  
Internal shade: none  
Blinds, drapes, etc.  
Number of skylights: 0

total number of  
occupant 1 more  
bedrooms



## HVAC EQUIPMENT SELECTION (IRC M1401.3)

### Heating Equipment Data

Equipment type: Gas furnace  
Furnace, Heat pump, Boiler, etc.  
Model: American Standard  
ADH1B040A9H21B\*  
Heating output capacity: 38000 Btuh  
Heat pumps - capacity at winter design outdoor conditions  
Aux. heating output capacity: 0 Btuh

### Cooling Equipment Data

Equipment type: Split AC  
Air Conditioner, Heat pump, etc.  
Model: American Standard  
4A7A3016H1  
Total cooling capacity: 0 Btuh  
Sensible cooling capacity: 0 Btuh  
Latent cooling capacity: 0 Btuh

### Blower Data

Heating cfm: 473  
Cooling cfm: 473  
Static pressure: 0.70 in H2O  
Fan's rated external static pressure for design airflow

this will only be 0 if  
under 18k btu

## HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 473 cfm	Longest supply duct: 228 ft	Duct Materials Used
Equipment design ESP: 0.70 in H2O	Longest return duct: 296 ft	Trunk duct:
Total device pressure losses: -0.4 in H2O	Total effective length (TEL): 524 ft	Branch duct:
Available static pressure (ASP): 0.34 in H2O	Friction rate: 0.065 in/100ft	

must have values

below .60 fails

make sure if flex is  
used its listed

Sheet metal  
Round flex vinyl

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed and I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: \_\_\_\_\_  
Contractor's signature: \_\_\_\_\_ must be signed \_\_\_\_\_ Date: \_\_\_\_\_

Reserved for County, Town Municipality or Authority having jurisdiction use.

\*Home qualifies for MJ1AE Form based on Abridged Edition Checklist

# Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form  
RPER 1  
15 Mar 09

## Header Information

Contractor:	company name	REQUIRED ATTACHMENTS	ATTACHED
Mechanical license:	your name	Manual J1 Form (and supporting worksheets):	Yes <input type="checkbox"/> No <input type="checkbox"/>
Building plan #:	**must have lic.	or MJ1AE Form* (and supporting worksheets):	Yes <input type="checkbox"/> No <input type="checkbox"/>
	type and #**	OEM performance data (heating, cooling, blower):	Yes <input type="checkbox"/> No <input type="checkbox"/>
		Manual D Friction Rate Worksheet:	Yes <input type="checkbox"/> No <input type="checkbox"/>
		Duct distribution sketch:	Yes <input type="checkbox"/> No <input type="checkbox"/>
Home address (Street or Lot#, Block, Subdivision):	123 main st, 2nd fl		

## HVAC LOAD CALCULATION (IRC M1401.3)

### Design Conditions

#### Winter Design Conditions

Outdoor temperature: 7 °F  
Indoor temperature: 70 °F  
Total heat loss: 22886 Btuh

#### Summer Design Conditions

Outdoor temperature: 83 °F  
Indoor temperature: 75 °F  
Grains difference: 25 gr/lb @ 50% RH  
Sensible heat gain: 10997 Btuh  
Latent heat gain: 1705 Btuh  
Total heat gain: 12702 Btuh

### Building Construction Information


#### Building

Orientation: Front Door faces Southwest  
North, East, West, South, Northeast, Northwest, Southeast, Southwest  
Number of bedrooms: 3  
Conditioned floor area: 1008 sq ft  
Number of occupants: 2

#### Windows

Eave overhang depth: 0 ft  
Internal shade: none  
Blinds, drapes, etc.  
Number of skylights: 0

additional 2 person  
total of 4



## HVAC EQUIPMENT SELECTION (IRC M1401.3)

### Heating Equipment Data

Equipment type: Gas furnace  
Furnace, Heat pump, Boiler, etc.  
Model: American Standard  
ADD2A040A9242A\*  
Heating output capacity: 32000 Btuh  
Heat pumps - capacity at winter design outdoor conditions  
Aux. heating output capacity: 0 Btuh

### Cooling Equipment Data

Equipment type: Split AC  
Air Conditioner, Heat pump, etc.  
Model: American Standard  
4A7A3018H1  
Total cooling capacity: 0 Btuh  
Sensible cooling capacity: 0 Btuh  
Latent cooling capacity: 0 Btuh

### Blower Data

Heating cfm: 470  
Cooling cfm: 470  
Static pressure: 0.70 in H2O  
Fan's rated external static pressure for design airflow

## HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow:	470 cfm	Longest supply duct:	329 ft	Duct Materials Used
Equipment design ESP:	0.70 in H2O	Longest return duct:	267 ft	Trunk duct:
Total device pressure losses:	-0.3 in H2O	Total effective length (TEL):	596 ft	Sheet metal
Available static pressure (ASP):	0.36 in H2O	Friction rate:	0.060 in/100ft	Branch duct:
		Friction Rate = ASP ÷ (TEL x 100)		Round flex vinyl

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: \_\_\_\_\_  
Contractor's signature: \_\_\_\_\_ Date: \_\_\_\_\_

Reserved for County, Town Municipality or Authority having jurisdiction use.

\*Home qualifies for MJ1AE Form based on Abridged Edition Checklist

company addresss, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

## Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	7	83	Method	Simplified
Inside db (°F)	70	75	Construction quality	Average
Design TD (°F)	63	8	Fireplaces	0
Daily range	-	L		
Inside humidity (%)	45	50		
Moisture difference (gr/lb)	45	25		

### HEATING EQUIPMENT

Make n/a  
Trade n/a  
Model n/a  
AHRI ref n/a

Efficiency  
Heating input  
Heating output 0 Btuh  
Temperature rise 0 °F  
Actual air flow 0 cfm  
Air flow factor 0 cfm/Btuh  
Static pressure 0 in H2O  
Space thermostat n/a

will be blank if  
home has more  
than 1 system

### COOLING EQUIPMENT

Make n/a  
Trade n/a  
Cond n/a  
Coil n/a  
AHRI ref n/a

Efficiency n/a  
Sensible cooling 0 Btuh  
Latent cooling 0 Btuh  
Total cooling 0 Btuh  
Actual air flow 0 cfm  
Air flow factor 0 cfm/Btuh  
Static pressure 0 in H2O  
Load sensible heat ratio 0

ROOM NAME		Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
2nd fl	d	1008	22435	9621	470	470
1stfl	d	1008	20145	9000	473	473
Entire House	d	2016	42581	18620	943	943
Other equip loads			451	57		
Equip. @ 0.88 RSM				16436		
Latent cooling				3045		
TOTALS		2016	43032	19481	943	943

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



company addresss, town your company is in License: \*\*must have lic. type and #\*\*

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

### Design Information

	Htg	Clg	Infiltration	
Outside db (°F)	7	83	Method	Simplified
Inside db (°F)	70	75	Construction quality	Average
Design TD (°F)	63	8	Fireplaces	0
Daily range	-	L		
Inside humidity (%)	40	50		
Moisture difference (gr/lb)	39	25		

#### HEATING EQUIPMENT

Make American Standard  
Trade AMERICAN STANDARD  
Model ADH1B040A9H21B\*  
AHRI ref 5722420  
Efficiency 95 AFUE  
Heating input 40000 Btuh  
Heating output 38000 Btuh  
Temperature rise 76 °F  
Actual air flow 473 cfm  
Air flow factor 0.023 cfm/Btuh  
Static pressure 0.70 in H2O  
Space thermostat

#### COOLING EQUIPMENT

Make American Standard  
Trade AMERICAN STANDARD  
Cond 4A7A3018H1  
Coil C(A,C,D,E)30B44+S9X2B040U3PS+TDR  
AHRI ref 10208688  
Efficiency 12.5 EER, 15 SEER  
Sensible cooling 12070 Btuh  
Latent cooling 2130 Btuh  
Total cooling 14200 Btuh  
Actual air flow 473 cfm  
Air flow factor 0.053 cfm/Btuh  
Static pressure 0.70 in H2O  
Load sensible heat ratio 0.84

must be filled in, good  
to check to see if it is  
actually whats there..

ROOM NAME	Area (ft²)	Htg load (Btuh)	AVF (n)	Clg AVF (cfm)	
living	208	4563	3060	107	161
den	196	4211	1574	99	83
kitchen	195	3794	2382	89	125
base stairs	40	0	0	0	0
lav	40	1802	603	42	32
dining	251	4388	1004	103	53
foyer/stairs	78	1389	376	33	20

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

1stfl	d	1008	20145	9000	473	473
Other equip loads			0	0		
Equip. @ 0.88 RSM				7920		
Latent cooling				1654		
TOTALS		1008	20145	9574	473	473

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2018 18.0.32 RSU06606

2019-May-12 17:04:32

Page 3

...smike\Dropbox\HVAC\shrewbury town template.rup Calc = MJ8 Front Door faces: SW

company addresss, town your company is in License: \*\*must have lic. type and #\*\*

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

### Design Information

	Htg	Clg	Method	Infiltration
Outside db (°F)	7	83	Construction quality	Simplified
Inside db (°F)	70	75	Fireplaces	Average
Design TD (°F)	63	8		0
Daily range	-	L		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	50	25		

masonry type only

new home should be tight to semi tight  
older ok to lean towards average and  
pre 80's may be loose

#### HEATING EQUIPMENT

Make American Standard  
Trade AMERICAN STANDARD  
Model ADD2A040A9242A\*  
AHRI ref 2016744

Efficiency 80 AFUE  
Heating input 40000 Btuh  
Heating output 32000 Btuh  
Temperature rise 64 °F  
Actual air flow 470 cfm  
Air flow factor 0.021 cfm/Btuh  
Static pressure 0.70 in H2O  
Space thermostat

#### COOLING EQUIPMENT

Make American Standard  
Trade ASPEN  
Cond 4A7A3018H1  
Coil C(A,C,D,E)30A2G+S9X2B040U3PS+TDR  
AHRI ref 10208692

Efficiency 11.8 EER, 14 SEER  
Sensible cooling 11985 Btuh  
Latent cooling 2115 Btuh  
Total cooling 14100 Btuh  
Actual air flow 470 cfm  
Air flow factor 0.049 cfm/Btuh  
Static pressure 0.70 in H2O  
Load sensible heat ratio 0.87

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
bed3	132	3692	2463	77	120
laundry	42	1217	259	25	13
bed2	120	2652	1413	56	69
closet2	49	1638	234	34	11
m bath	80	1712	365	36	18
wi	60	1909	276	40	14
bath	63	1612	319	34	16
stair an hall	140	0	0	0	0
bed4	70	2029	647	42	32
master	252	5975	3642	125	178

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

2nd fl	d	1008	22435	9621	470	470
Other equip loads			451	57		
Equip. @ 0.88 RSM				8516		
Latent cooling				1500		
TOTALS		1008	22886	10016	470	470

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Right-Suite® Universal 2018 18.0.32 RSU06606

2019-May-12 17:04:32

Page 5

...smike\Dropbox\HVAC\shrewbury town template.rup Calc = MJ8 Front Door faces: SW

company addresss, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

## Design Conditions

### Location:

Worcester Regional AP, MA, US  
Elevation: 1017 ft  
Latitude: 42°N

must be your area

### Indoor:

Indoor temperature (°F)  
Design TD (°F)  
Relative humidity (%)  
Moisture difference (gr/lb)

### Heating

70  
63  
45  
44.6

### Cooling

75  
8  
50  
24.9

### Outdoor:

Dry bulb (°F)  
Daily range (°F)  
Wet bulb (°F)  
Wind speed (mph)

### Heating

7  
-  
-  
15.0

### Cooling

83  
16 ( L )  
70  
7.5

these values are from location data

### Infiltration:

Method  
Construction quality  
Fireplaces

Simplified  
Average  
0

## Construction descriptions

### Walls

12C-0sw: Fm wall, vnl ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int fnsh, 2"x6" wood frm, 16" o.c. stud

Or	Area ft²	U-value Btuh/ft²°F	Insul R ft²°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
n	499	0.065	21.0	4.11	2053	0.68	337
e	388	0.065	21.0	4.11	1596	0.68	262
s	468	0.065	21.0	4.11	1926	0.68	316
w	385	0.065	21.0	4.11	1584	0.68	260
all	1740	0.065	21.0	4.11	7159	0.68	1176

### Partitions (none)

wall r value

### Windows

10C-w: 2 glazing, clr low-e outr, air gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk; NFRC rated (SHGC=0.24); 6.67 ft head ht

2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk;  
2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk;  
6.67 ft head ht

n	35	0.300	0	19.0	665	4.89	171
e	42	0.300	0	19.0	798	8.13	341
s	60	0.300	0	19.0	1139	30.6	1833
w	87	0.300	0	19.0	1652	15.5	1347
all	231	0.300	0	19.0	4387	20.8	4805

window u values

### Doors

11D0: Door, wd sc type

s	21	0.390	0	24.7	518	8.42	177
w	21	0.390	0	24.7	518	8.42	177
all	42	0.390	0	24.7	1037	8.42	354

### Ceilings

16B-50ad: Attic ceiling, asphalt shingles roof mat, r-50 ceil ins, 1/2" gypsum board int fnsh

	1008	0.020	50.0	1.27	1276	0.90	909
	1008	0.020	50.0	1.27	1276	0.90	909
all	2016	0.020	50.0	1.27	2552	0.90	1818

attic r value

### Floors

19A-0bswp: Part floor, hrd wd flr fnsh, frm flr, 10" thkns, 1/2" gypsum board int fnsh

19A-38bswp: Flr floor, frm flr, 10" thkns, hrd wd flr fnsh, r-38 cav ins, tight bsmt ovr

	1008	0.295	0	7.01	7071	0.89	894
	1008	0.029	38.0	1.58	1591	0.20	201

floor insulation r value





**wrightsoft®**  
A Mitel® / Berkshire Hathaway Company

Right-Suite® Universal 2018 18.0.32 RSU06606

...\\smike\\Dropbox\\HVAC\\shrewbury town\\template.rup Calc = MJ8 Front Door faces: SW

2019-May-12 17:04:32

Page 2



company addresss, town your company is in License: \*\*must have lic. type and #\*\*

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

### Design Conditions

#### Location:

Worcester Regional AP, MA, US  
Elevation: 1017 ft  
Latitude: 42°N

#### Outdoor:

Dry bulb (°F)  
Daily range (°F)  
Wet bulb (°F)  
Wind speed (mph)

#### Heating

7  
-  
-  
15.0

#### Cooling

83  
16 ( L )  
70  
7.5

#### Indoor:

Indoor temperature (°F)  
Design TD (°F)  
Relative humidity (%)  
Moisture difference (gr/lb)

#### Infiltration:

Method  
Construction quality  
Fireplaces

#### Heating

70  
63  
40  
38.9

#### Cooling

75  
8  
50  
24.9

Simplified  
Average  
0

### Construction descriptions

#### Walls

12F-0sw: Fm wall, vnl ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int fnsh, 2"x6" wood frm, 16" o.c. stud

Or	Area ft²	U-value Btuh/ft²°F	Insul R ft²°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
n	241	0.065	21.0	4.11	992	0.68	163
e	200	0.065	21.0	4.11	823	0.68	135
s	219	0.065	21.0	4.11	901	0.68	148
w	185	0.065	21.0	4.11	761	0.68	125
all	845	0.065	21.0	4.11	3477	0.68	571

#### Partitions

(none)

#### Windows

10C-w: 2 glazing, clr low-e outr, air gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk; NFRC rated (SHGC=0.24); 6.67 ft head ht

2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk;  
2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk;  
6.67 ft head ht

n	35	0.300	0	19.0	665	4.89	171
e	12	0.300	0	19.0	228	8.13	98
s	24	0.300	0	19.0	456	30.6	733
w	48	0.300	0	19.0	912	15.5	743
w	18	0.300	0	19.0	342	30.6	550
all	102	0.300	0	19.0	1937	20.8	2124

#### Doors

11D0: Door, wd sc type

s	21	0.390	0	24.7	518	8.42	177
w	21	0.390	0	24.7	518	8.42	177
all	42	0.390	0	24.7	1037	8.42	354

#### Ceilings

16B-50ad: Attic ceiling, asphalt shingles roof mat, r-50 ceil ins, 1/2" gypsum board int fnsh

1008	0.020	50.0	1.27	1276	0.90	909
------	-------	------	------	------	------	-----

#### Floors

19A-38bswp: Flr floor, frm flr, 10" thkns, hrd wd flr fnsh, r-38 cav ins, tight bsmt ovr

1008	0.029	38.0	1.58	1591	0.20	201
------	-------	------	------	------	------	-----

company addresss, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

## Design Conditions

Location:		Indoor:		Heating	Cooling
Worcester Regional AP, MA, US		Indoor temperature (°F)		70	75
Elevation: 1017 ft		Design TD (°F)		63	8
Latitude: 42°N		Relative humidity (%)		50	50
		Moisture difference (gr/lb)		50.4	24.9
Outdoor:		Heating	Cooling		
Dry bulb (°F)		7	83		
Daily range (°F)		-	16 ( L )		
Wet bulb (°F)		-	70		
Wind speed (mph)		15.0	7.5		
		Infiltration:			
		Method		Simplified	
		Construction quality		Average	
		Fireplaces		0	

## Construction descriptions

	Or	Area ft²	U-value Btuh/ft²·°F	Insul R ft²·°F/Btuh	Htg HTM Btuh/ft²	Loss Btuh	Clg HTM Btuh/ft²	Gain Btuh
Walls 12F-0sw: Frm wall, vnl ext, 1/2" wood shth, r-21 cav ins, 1/2" gypsum board int fnsh, 2"x6" wood frm, 16" o.c. stud	n	258	0.065	21.0	4.11	1062	0.68	174
	e	188	0.065	21.0	4.11	774	0.68	127
	s	249	0.065	21.0	4.11	1025	0.68	168
	w	200	0.065	21.0	4.11	823	0.68	135
	all	895	0.065	21.0	4.11	3682	0.68	605

## Partitions

(none)

## Windows

2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk; 2 glazing, clr low-e outr, argon gas, wd frm mat, clr innr, 1/4" gap, 1/8" thk; 6.67 ft head ht	n	30	0.300	0	19.0	570	8.13	244
	e	36	0.300	0	19.0	684	30.6	1100
	s	39	0.300	0	19.0	741	15.5	604
	w	24	0.300	0	19.0	456	30.6	733
	all	129	0.300	0	19.0	2450	20.8	2681

## Doors

(none)

## Ceilings

16B-50ad: Attic ceiling, asphalt shingles roof mat, r-50 ceil ins, 1/2" gypsum board int fnsh	1008	0.020	50.0	1.27	1276	0.90	909
---	------	-------	------	------	------	------	-----

## Floors

19A-0bswp: Part floor, hrd wd flr fnsh, frm flr, 10" thkns, 1/2" gypsum board int fnsh	1008	0.295	0	7.01	7071	0.89	894
--	------	-------	---	------	------	------	-----

no r value do to in conditioned space

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

Notes:

### Design Information

Weather: Worcester Regional AP, MA, US

very important

#### Winter Design Conditions

Outside db 7 °F  
Inside db 70 °F  
Design TD 63 °F

#### Summer Design Conditions

Outside db 83 °F  
Inside db 75 °F  
Design TD 8 °F  
Daily range L  
Relative humidity 50 %  
Moisture difference 25 gr/lb

#### Heating Summary

Structure 37088 Btuh  
Ducts 5492 Btuh  
Central vent (7 cfm) 451 Btuh  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 43032 Btuh

#### Sensible Cooling Equipment Load Sizing

Structure 14760 Btuh  
Ducts 3860 Btuh  
Central vent (7 cfm) 57 Btuh  
Blower 0 Btuh  
Use manufacturer's data n  
Rate/swing multiplier 0.88  
Equipment sensible load 16436 Btuh

Infiltration  
If new home must have mechanical ventilation

Method  
Construction quality  
Fireplaces

#### Latent Cooling Equipment Load Sizing

Structure 2376 Btuh  
Ducts 668 Btuh  
Central vent (7 cfm) 109 Btuh

	Heating	Cooling
Area (ft²)	2016	2016
Volume (ft³)	16128	16128
Air changes/hour	0.41	0.21
Equiv. AVF (cfm)	110	56

Equipment latent load 3045 Btuh

**Equipment Total Load (Sen+Lat)** 19481 Btuh  
Req. total capacity at 0.70 SHR 2.0 ton

#### Heating Equipment Summary

Make	n/a
Trade	n/a
Model	n/a
AHRI ref	n/a
Efficiency	n/a
Heating input	0 Btuh
Heating output	0 °F
Temperature rise	0 cfm
Actual air flow	0 cfm/Btuh
Air flow factor	0 in H2O
Static pressure	n/a
Space thermostat	

#### Cooling Equipment Summary

Make	n/a
Trade	n/a
Cond	n/a
Coil	n/a
AHRI ref	n/a
Efficiency	n/a
Sensible cooling	0 Btuh
Latent cooling	0 Btuh
Total cooling	0 Btuh
Actual air flow	0 cfm
Air flow factor	0 cfm/Btuh
Static pressure	0 in H2O
Load sensible heat ratio	0

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

Notes:

### Design Information

Weather: Worcester Regional AP, MA, US

#### Winter Design Conditions

Outside db 7 °F  
Inside db 70 °F  
Design TD 63 °F

#### Summer Design Conditions

Outside db 83 °F  
Inside db 75 °F  
Design TD 8 °F  
Daily range L  
Relative humidity 50 %  
Moisture difference 25 gr/lb

#### Heating Summary

Structure 17378 Btuh  
Ducts 2768 Btuh  
Central vent (0 cfm) 0 Btuh  
Outside air  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 20145 Btuh

#### Sensible Cooling Equipment Load Sizing

Structure 7069 Btuh  
Ducts 1930 Btuh  
Central vent (0 cfm) 0 Btuh  
Outside air  
Blower 0 Btuh  
Use manufacturer's data n  
Rate/swing multiplier 0.88  
Equipment sensible load 7920 Btuh

#### Infiltration

Method Simplified  
Construction quality Average  
Fireplaces 0

#### Latent Cooling Equipment Load Sizing

Structure 1320 Btuh  
Ducts 334 Btuh  
Central vent (0 cfm) 0 Btuh  
Outside air  
Equipment latent load 1654 Btuh

	Heating	Cooling
Area (ft²)	1008	1008
Volume (ft³)	8064	8064
Air changes/hour	0.82	0.42
Equiv. AVF (cfm)	110	56

**Equipment Total Load (Sen+Lat)** 9574 Btuh  
Req. total capacity at 0.85 SHR 0.8 ton

#### Heating Equipment Summary

Make American Standard  
Trade AMERICAN STANDARD  
Model ADH1B040A9H21B\*  
AHRI ref 5722420  
Efficiency 95 AFUE  
Heating input 40000 Btuh  
Heating output 38000 Btuh  
Temperature rise 76 °F  
Actual air flow 473 cfm  
Air flow factor 0.023 cfm/Btuh  
Static pressure 0.70 in H2O  
Space thermostat

#### Cooling Equipment Summary

Make American Standard  
Trade AMERICAN STANDARD  
Cond 4A7A3018H1  
Coil C(A,C,D,E)30B44+S9X2B040U3PS+TDR  
AHRI ref 10208688  
Efficiency 12.5 EER, 15 SEER  
Sensible cooling 12070 Btuh  
Latent cooling 2130 Btuh  
Total cooling 14200 Btuh  
Actual air flow 473 cfm  
Air flow factor 0.053 cfm/Btuh  
Static pressure 0.70 in H2O  
Load sensible heat ratio 0.84

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

Notes:

### Design Information

Weather: Worcester Regional AP, MA, US

#### Winter Design Conditions

Outside db 7 °F  
Inside db 70 °F  
Design TD 63 °F

#### Summer Design Conditions

Outside db 83 °F  
Inside db 75 °F  
Design TD 8 °F  
Daily range L  
Relative humidity 50 %  
Moisture difference 25 gr/lb

mechanical  
ventilation

#### Heating Summary

Structure 19711 Btuh  
Ducts 2725 Btuh  
Central vent (7 cfm) 451 Btuh  
Outside air 0 Btuh  
Humidification 0 Btuh  
Piping 0 Btuh  
Equipment load 22886 Btuh

#### Sensible Cooling Equipment Load Sizing

Structure 7691 Btuh  
Ducts 1930 Btuh  
Central vent (7 cfm) 57 Btuh  
Outside air 0 Btuh  
Blower 0 Btuh

#### Infiltration

Method Simplified  
Construction quality Average  
Fireplaces 0

#### Latent Cooling Equipment Load Sizing

Structure 1057 Btuh  
Ducts 334 Btuh  
Central vent (7 cfm) 109 Btuh  
Outside air 1500 Btuh  
Equipment latent load 1500 Btuh

Area (ft²) 1008  
Volume (ft³) 8064  
Air changes/hour 0.58  
Equiv. AVF (cfm) 78

Equipment Total Load (Sen+Lat) 10016 Btuh  
Req. total capacity at 0.85 SHR 0.8 ton

#### Heating Equipment Summary

Make American Standard  
Trade AMERICAN STANDARD  
Model ADD2A040A9242A\*  
AHRI ref 2016744  
Efficiency 80 AFUE  
Heating input 40000 Btuh  
Heating output 32000 Btuh  
Temperature rise 64 °F  
Actual air flow 470 cfm  
Air flow factor 0.021 cfm/Btuh  
Static pressure 0.70 in H2O  
Space thermostat

#### Cooling Equipment Summary


Make American Standard  
Trade ASPEN  
Cond 4A7A3018H1  
Coil C(A,C,D,E)30A2G+S9X2B040U3PS+TDR  
AHRI ref 10208692  
Efficiency 11.8 EER, 14 SEER  
Sensible cooling 11985 Btuh  
Latent cooling 2115 Btuh  
Total cooling 14100 Btuh  
Actual air flow 470 cfm  
Air flow factor 0.049 cfm/Btuh  
Static pressure 0.70 in H2O  
Load sensible heat ratio 0.87

must be complete

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



## attic



**Job #: 1234**  
**Performed by mb for:**  
contractor name  
123 main st  
town you are working in, ma 12345  
Phone: must have contact#

**company name**

company address  
town your company is in


**Scale: 1 : 63**

Page 1  
RightSuite® Universal 2018  
18.0.32 RSU06606  
2019-May-12 17:04:55  
...HVAC's hrewbury town template.rup





## 2nd floor




Job #: 1234  
Performed by mb for:  
contractor name  
123 main st  
town you are working in, ma 12345  
Phone: must have contact#

company name


company address  
town your company is in

Scale: 1 : 63

Page 2  
RightSuite® Universal 2018  
18.0.32 RSU06606  
2019-May-12 17:04:55  
...HVAC\shrewburytown template.rup



## 1st floor



**Job #: 1234**  
**Performed by mb for:**  
contractor name  
123 main st  
town you are working in, ma 12345  
Phone: must have contact#

**company name**


company address  
town your company is in

**Scale: 1 : 63**

Page 3  
RightSuite® Universal 2018  
18.0.32 RSU06606  
2019-May-12 17:04:55  
...HVAC'shrewburytown template.rup



## basement



Job #: 1234  
Performed by mb for:  
contractor name  
123 main st  
town you are working in, ma 12345  
Phone: must have contact#

company name

company address  
town your company is in

Scale: 1 : 63

Page 4  
RightSuite® Universal 2018  
18.0.32 RSU06606  
2019-May-12 17:04:55  
...HVAC'shrewburytown template.rup

# Duct System Summary

1stfl

company name

Job: 1234  
Date: Dec. 30th 2018  
By: mb

company address, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

	Heating	Cooling
External static pressure	0.70 in H2O	0.70 in H2O
Pressure losses	0.36 in H2O	0.36 in H2O
Available static pressure	0.34 in H2O	0.34 in H2O
Supply / return available pressure	0.148 / 0.192 in H2O	0.148 / 0.192 in H2O
Lowest friction rate	0.065 in/100ft	0.065 in/100ft
Actual air flow	473 cfm	473 cfm
Total effective length (TEL)	524 ft	

## Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
den	h 4211	99	83	0.072	6.0	0x0	VFx	16.0	190.0	st2
dining	h 4388	103	53	0.075	6.0	0x0	VFx	23.0	175.0	st2
foyer/stairs	h 1389	33	20	0.071	5.0	0x0	VFx	27.0	180.0	st2
kitchen	c 2382	89	125	0.074	7.0	0x0	VFx	36.0	165.0	st2
lav	h 1802	42	32	0.075	5.0	0x0	VFx	11.0	185.0	st2
living	c 3060	107	161	0.065	8.0	0x0	VFx	43.0	185.0	st2A

flex

## Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st2	Peak AVF	473	473	0.065	608	11.4	8 x 14	ShtMetl	st2
st2A	Peak AVF	107	161	0.065	362	7.6	8 x 8	ShtMetl	

try to keep under 700 fpm

metal

## Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb23	0x0	244	167	179.0	0.107	448	10.0	0x0		VFx	rt2
rb24	0x0	229	306	296.0	0.065	561	10.0	0x0		VFx	rt2

## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt2	Peak AVF	473	473	0.065	608	11.4	8 x 14	ShtMetl	

company addresss, town your company is in License: \*\*must have lic. type and #\*\*

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

	Heating	Cooling
External static pressure	0.70 in H2O	0.70 in H2O
Pressure losses	0.34 in H2O	0.34 in H2O
Available static pressure	0.36 in H2O	0.36 in H2O
Supply / return available pressure	0.199 / 0.161 in H2O	0.199 / 0.161 in H2O
Lowest friction rate	0.060 in/100ft	0.060 in/100ft
Actual air flow	470 cfm	470 cfm
Total effective length (TEL)	596 ft	

### Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
bath	h 1612	34	16	0.066	<b>4.0</b>	<b>0x0</b>	VIFx	54.5	245.0	st3
bed2	c 1413	56	69	0.070	<b>6.0</b>	<b>0x0</b>	VIFx	40.0	245.0	st3
bed3	c 2463	77	120	0.081	<b>6.0</b>	<b>0x0</b>	VIFx	19.0	225.0	st3
bed4	h 2029	42	32	0.072	<b>5.0</b>	<b>0x0</b>	VIFx	11.0	265.0	st4
closet2	h 1638	34	11	0.071	<b>4.0</b>	<b>0x0</b>	VIFx	49.0	230.0	st3
laundry	h 1217	25	13	0.064	<b>4.0</b>	<b>0x0</b>	VIFx	64.0	245.0	st4
m bath	h 1712	36	18	0.068	5.0	0x0	VIFx	59.0	235.0	st4
master	c 3642	125	178	0.078	<b>8.0</b>	<b>0x0</b>	VIFx	25.0	230.0	st4
wi	h 1909	40	14	0.060	6.0	0x0	VIFx	49.0	280.0	st4

overridden values are ok as long as not to many than design is after thought

### Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st4	Peak AVF	269	254	0.060	493	10.0	0 x 0	ShtMetl	st1
st3	Peak AVF	201	216	0.066	490	9.0	0 x 0	ShtMetl	st1
st1	Peak AVF	470	470	0.060	598	12.0	0 x 0	ShtMetl	

*Bold/italic values have been manually overridden*

will only display if values have been overridden may be turned off thou



## Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	201	209	135.0	0.119	384	<b>10.0</b>	<b>0x 0</b>		VIFx	rt1
rb25	0x0	59	28	201.0	0.080	302	6.0	0x 0		VIFx	rt1
rb2	0x0	77	120	196.4	0.082	345	8.0	0x 0		VIFx	rt1
rb5	0x0	42	32	102.0	0.158	312	5.0	0x 0		VIFx	rt1
rb3	0x0	90	81	267.0	0.060	257	8.0	0x 0		VIFx	rt1

## Return Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
rt1	Peak AVF	470	470	0.060	598	12.0	0 x 0	ShtMetl	

*Bold/italic values have been manually overridden*



company address, town your company is in License: \*\*must have lic. type and #\*\*

### Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

### Available Static Pressure

	Heating (in H <sub>2</sub> O)	Cooling (in H <sub>2</sub> O)	
External static pressure	0.70	0.70	should not be over .80 to start
Pressure losses			
Coil	0.12	0.12	
Heat exchanger	0	0	
Supply diffusers	0.03	0.03	
Return grilles	0.03	0.03	
Filter	0.15	0.15	all filters have diff. values
Humidifier	0	0	
Balancing damper	0.03	0.03	
Other device	0	0	
Available static pressure	0.34	0.34	

### Total Effective Length

	Supply (ft)	Return (ft)
Measured length of run-out	15	3
Measured length of trunk	28	23
Equivalent length of fittings	185	270
Total length	228	296
Total effective length		524

### Friction Rate

	Heating (in/100ft)		Cooling (in/100ft)	
Supply Ducts	0.065	OK	0.065	OK
Return Ducts	0.065	OK	0.065	OK

### Fitting Equivalent Length Details

Supply	4G=80, 2K0=50, 12H1=20, 1C=35: TotalEL=185
Return	6M=20, 6C6=115, 8B7=65, 6CB=25, 5H1=45: TotalEL=270

must say ok

company address, town your company is in License: \*\*must have lic. type and #\*\*

## Project Information

For: contractor name, your co name  
123 main st, town you are working in, ma 12345  
Phone: must have contact #

## Available Static Pressure

	Heating (in H2O)	Cooling (in H2O)
External static pressure	0.70	0.70
Pressure losses		
Coil	0.10	0.10
Heat exchanger	0	0
Supply diffusers	0.03	0.03
Return grilles	0.03	0.03
Filter	0.15	0.15
Humidifier	0	0
Balancing damper	0.03	0.03
Other device	0	0
Available static pressure	0.36	0.36

diff coils will have diff values

all highlighted values are constant

## Total Effective Length

	Supply (ft)	Return (ft)
Measured length of run-out	3	5
Measured length of trunk	46	7
Equivalent length of fittings	280	255
Total length	329	267
Total effective length		596

## Friction Rate

	Heating (in/100ft)	Cooling (in/100ft)
Supply Ducts	0.060	0.060
Return Ducts	0.060	0.060

OK OK

OK OK

## Fitting Equivalent Length Details

Supply	4AD=60, 9I1=85, 8AE=10, 9I2=5, 9I1=85, 1A=35: TotalEL=280
Return	6M=20, 6A6=75, 6AA=10, 10G=75, 6AB=25, 6AA=10, 5D=40: TotalEL=255

below .60 fails

Robert Berger is inviting you to a scheduled Zoom meeting.

Topic: October 18 2022 Metro-West Meeting

Time: Oct 18, 2022 09:00 AM Eastern Time (US and Canada)

Join Zoom Meeting

<https://us06web.zoom.us/j/82935069329?pwd=OTBJTON4TmhaY2VDbE1JNkFVbXNxQT09>

Meeting ID: 829 3506 9329

Passcode: 129425

One tap mobile

+13092053325,,82935069329#,,,,\*129425# US

+13126266799,,82935069329#,,,,\*129425# US (Chicago)

Dial by your location

+1 309 205 3325 US

+1 312 626 6799 US (Chicago)

+1 646 558 8656 US (New York)

+1 646 931 3860 US

+1 301 715 8592 US (Washington DC)

+1 253 215 8782 US (Tacoma)

+1 346 248 7799 US (Houston)

+1 386 347 5053 US

+1 564 217 2000 US

+1 669 444 9171 US

+1 719 359 4580 US

+1 720 707 2699 US (Denver)

Meeting ID: 829 3506 9329

Passcode: 129425

Find your local number: <https://us06web.zoom.us/j/82935069329>